

Lead in Drinking Water Analytical Results Summary
 Citizenship Science Academy of Syracuse
 Middle School
 7053 Buckley Rd, Syracuse, New York

School / Sample Identification #	Date/Time Collected	Sample Location	Total Lead (ug/L)
CSAS-MS-1	4/16/2025 08:25	Nurse Exam Room	7.3
CSAS-MS-2	4/16/2025 08:26	Nurse Restroom	1.8
CSAS-MS-3	4/16/2025 08:27	129 - Library Work Room	53.9
CSAS-MS-4	4/16/2025 08:31	131 - Art Sink 1	3.0
CSAS-MS-5	4/16/2025 08:32	131 - Art Sink 2	1.4
CSAS-MS-6	4/16/2025 08:33	131 - Art Sink 3	3.7
CSAS-MS-7	4/16/2025 08:35	133 - Staff Lounge	8.5
CSAS-MS-8	4/16/2025 08:38	Girl's Restroom next 133 (Left)	<1.0
CSAS-MS-9	4/16/2025 08:39	Girl's Restroom next 133 (Left Middle)	1.9
CSAS-MS-10	4/16/2025 08:40	Girl's Restroom next 133 (Middle)	4.9
CSAS-MS-11	4/16/2025 08:41	Girl's Restroom next 133 (Right Middle)	<1.0
CSAS-MS-12	4/16/2025 08:42	Girl's Restroom next 133 (Right)	<1.0
CSAS-MS-13	4/16/2025 08:51	Boy's Restroom next 133 (Left)	5.5
CSAS-MS-14	4/16/2025 08:52	Boy's Restroom next 133 (Left Middle)	<1.0
CSAS-MS-15	4/16/2025 08:53	Boy's Restroom next 133 (Right Middle)	<1.0
CSAS-MS-16	4/16/2025 08:54	Boy's Restroom next 133 (Right)	<1.0
CSAS-MS-17	4/16/2025 08:57	Drinking Fountain next 137	<1.0
CSAS-MS-18	4/16/2025 08:58	Bottle Fountain next 137	<1.0
CSAS-MS-19	4/16/2025 09:00	Staff Restroom Men's next 137	1.6
CSAS-MS-20	4/16/2025 09:03	137 - Drinking Fountain	<1.0
CSAS-MS-21	4/16/2025 09:04	137 - Classroom Sink	<1.0
CSAS-MS-22	4/16/2025 09:11	Kitchen - 3 Bay (Left)	1.7
CSAS-MS-23	4/16/2025 09:12	Kitchen - 3 Bay (Right)	<1.0
CSAS-MS-24	4/16/2025 09:13	Kitchen - Hand Wash	11.2
CSAS-MS-25	4/16/2025 09:14	Kitchen - Restroom	2.9
CSAS-MS-26	4/16/2025 09:16	Kitchen - Staff Restroom	4.7
CSAS-MS-27	4/16/2025 09:20	138 - Drinking Fountain	<1.0
CSAS-MS-28	4/16/2025 09:21	138 - Classroom Sink	<1.0
CSAS-MS-29	4/16/2025 09:22	140 - Drinking Fountain	<1.0
CSAS-MS-30	4/16/2025 09:23	140 - Classroom Sink	<1.0
CSAS-MS-31	4/16/2025 09:25	142 - Drinking Fountain	<1.0
CSAS-MS-32	4/16/2025 09:26	142 - Classroom Sink	<1.0
CSAS-MS-33	4/16/2025 09:29	143 - Drinking Fountain	<1.0
CSAS-MS-34	4/16/2025 09:30	143 - Classroom Sink	<1.0
CSAS-MS-35	4/16/2025 09:32	141 - Drinking Fountain	<1.0
CSAS-MS-36	4/16/2025 09:34	141 - Classroom Sink	<1.0
CSAS-MS-37	4/16/2025 09:37	139 - Drinking Fountain	<1.0
CSAS-MS-38	4/16/2025 09:38	139 - Classroom Sink	<1.0
CSAS-MS-39	4/16/2025 09:42	Drinking Fountain Lower Level	4.7
CSAS-MS-40	4/16/2025 09:49	007 - PE Office Restroom	30.3
CSAS-MS-41	4/16/2025 09:51	Custodian Office Kitchenette	<1.0
CSAS-MS-42	4/16/2025 09:52	Boy's Locker room	13.0
CSAS-MS-43	4/16/2025 09:53	Girl's Locker room	78.6

Lead in Drinking Water Analytical Results Summary
 Citizenship Science Academy of Syracuse
 Middle School
 7053 Buckley Rd, Syracuse, New York

CSAS-MS-44	4/16/2025 10:03	122 - Drinking Fountain	<1.0
CSAS-MS-45	4/16/2025 10:04	122 - Classroom Sink	<1.0
CSAS-MS-46	4/16/2025 10:06	124 - Drinking Fountain	<1.0
CSAS-MS-47	4/16/2025 10:07	124 - Classroom Sink	<1.0
CSAS-MS-48	4/16/2025 10:10	126 - Drinking Fountain	<1.0
CSAS-MS-49	4/16/2025 10:11	126 - Classroom Sink	<1.0
CSAS-MS-50	4/16/2025 10:13	127 - Drinking Fountain	<1.0
CSAS-MS-51	4/16/2025 10:14	127 - Classroom Sink	<1.0
CSAS-MS-52	4/16/2025 10:16	125 - Drinking Fountain	<1.0
CSAS-MS-53	4/16/2025 10:17	125 - Classroom Sink	<1.0
CSAS-MS-54	4/16/2025 10:24	123 - Drinking Fountain	<1.0
CSAS-MS-55	4/16/2025 10:25	123 - Classroom Sink	1.5
CSAS-MS-56	4/16/2025 10:27	Staff Restroom next 108 (Left)	3.4
CSAS-MS-57	4/16/2025 10:31	Drinking Fountain next 108	1.5
CSAS-MS-58	4/16/2025 10:32	Staff Restroom next 108 (Right)	1.7
CSAS-MS-59	4/16/2025 10:33	Main Office Work Room	4.0
CSAS-MS-60	4/16/2025 10:40	8th/9th Boy's Restroom (Left)	<1.0
CSAS-MS-61	4/16/2025 10:41	8th/9th Boy's Restroom (Left Middle)	<1.0
CSAS-MS-62	4/16/2025 10:42	8th/9th Boy's Restroom (Right Middle)	<1.0
CSAS-MS-63	4/16/2025 10:43	8th/9th Boy's Restroom (Right)	<1.0
CSAS-MS-64	4/16/2025 10:44	8th/9th Girl's Restroom (Left)	<1.0
CSAS-MS-65	4/16/2025 10:45	8th/9th Girl's Restroom (Left Middle)	<1.0
CSAS-MS-66	4/16/2025 10:46	8th/9th Girl's Restroom (Right Middle)	<1.0
CSAS-MS-67	4/16/2025 10:47	8th/9th Girl's Restroom (Right)	<1.0
CSAS-MS-68	4/16/2025 10:48	121 - Drinking Fountain	3.4
CSAS-MS-69	4/16/2025 10:49	121 - Classroom Sink	10.5
CSAS-MS-70	4/16/2025 10:57	120 - Drinking Fountain	3.2
CSAS-MS-71	4/16/2025 10:58	120 - Classroom Sink	3.1
CSAS-MS-72	4/16/2025 10:59	119 - Drinking Fountain	1.2
CSAS-MS-73	4/16/2025 11:00	119 - Classroom Sink	1.5
CSAS-MS-74	4/16/2025 11:10	114 - Drinking Fountain	<1.0
CSAS-MS-75	4/16/2025 11:11	114 - Classroom Sink	5.1
CSAS-MS-76	4/16/2025 11:12	116 - Drinking Fountain	1.7
CSAS-MS-77	4/16/2025 11:13	116 - Classroom Sink	<1.0
CSAS-MS-78	4/16/2025 11:14	118 - Drinking Fountain	1.0
CSAS-MS-79	4/16/2025 11:15	118 - Classroom Sink	1.5
CSAS-MS-80	4/16/2025 11:16	117 - Drinking Fountain	2.7
CSAS-MS-81	4/16/2025 11:17	117 - Classroom Sink	5.6
CSAS-MS-82	4/16/2025 11:20	115 - Drinking Fountain	<1.0
CSAS-MS-83	4/16/2025 11:21	115 - Classroom	<1.0
CSAS-MS-84	4/16/2025 11:23	113 - Drinking Fountain	<1.0
CSAS-MS-85	4/16/2025 11:25	113 - Classroom Sink	1.4

Notes:

Exceedances of New York Department of Health (NYSDOH) Action Level for Lead In School Drinking Water (5 ppb) are highlighted.

ug/L - micrograms per liter or part per billion (ppb)